







# TRANSMISSION SYSTEM

## EARTHQUAKE READINESS





# HIGH VOLTAGE SUBSTATIONS



# RISK REDUCTION SOLUTIONS

DETERMINE RISK  
Identify And Quantify Potential Losses

## IDENTIFY STRATEGIES

Design Strategies

Business Strategies

Response Strategies

Reduce  
Hazard

Reduce  
Vulnerability


Accept Risks

Response plan  
and Materials

Emergency  
Operation Centers

Evaluate and Select Optimal Combination of Strategies





## Great Historic Earthquakes in Chile


1575 Valdivia	8.5
1730 Valparaíso	8.7
1751 Concepción	8.5
1835 Concepción	8.5
1868 Arica	9.0
1906 Valparaíso	8.2
1922 Vallenar	8.5
1943 Coquimbo	8.2
1960 Valdivia	9.5
1985 Santiago	8.0
1995 Antofagasta	8.0
2010 Maule	8.8



# China 2008, 220 kV Substation







**Tower**

**Earthquake Fault**



# Landslides

## Taiwan Earthquake



New Zealand, 1968  
66 kV

# Rock Falls




## Tramin Italy 2014 Earthquake





# TSUNAMI VULNERABILITY

JAPAN





WWW.JSCE.ORG



## Arrester Failure



Radiator  
Removed  
Manifold  
Leakage



# TRANSFORMER VULNERABILITIES





# SYSTEM EARTHQUAKE (Extreme Event) RISK ASSESSMENT





- System Inventory
- Component Fragility
- Scenario Earthquakes
- SERA Results

- Originally developed for Southern California Edison (SCE), 1990
- Used to evaluate the San Francisco BART system




# SERA MODEL






# TRANSFORMER VULNERABILITIES





950000. 2940000.

5124684. 2940000.




## EARTHQUAKE EXERCISE: M9 CASCADIA SUBDUCTION ZONE





One Line Diagrams  
GRAPHICAL DAMAGE DATA

# FUNCTIONAL FAILURE






# Seismic Mitigation

- BUILDINGS


## Structural and Nonstructural








# SUBSTATION SEISMIC MITIGATION PROGRAM






# SUBSTATION SEISMIC MITIGATION PROGRAM

## Rigid Bus Riser



**Earthquake Damage**

## Mitigation: Flexible Bus Riser




**Flexible Cable**



# Disconnect Switch




**Structural Bracing**



**Flexible Connections**


# SUBSTATION SEISMIC MITIGATION PROGRAM

## FIELD RETRO-FIT INSTALLATION OF A RING SPRING FRICTION DAMPER





# Seismic Vulnerability of High Voltage Power Transformers (460kV) and Base Isolation Options



# TRANSMISSION TOWER SEISMIC MITIGATION PROGRAM



**COLUMBIA RIVER**



**WILLAMETTE RIVER**





# IEEE Recommended Practice for Seismic Design of Substations

IEEE Power Engineering Society



Sponsored by the  
Substations Committee

693<sup>TM</sup>

IEEE  
3 Park Avenue  
New York, NY 10016-5997, USA


8 May 2006

IEEE Std 693™-2005  
(Revision of IEEE Std 693-1997)






# NEW SEISMICALLY DESIGNED SUBSTATION






# Infrastructure Systems

- Contemporary complex infrastructure systems
  - Essential for modern society function
  - Large scale and high exposure systems
  - Reached accelerated phase of aging and deterioration
  - More interdependent for optimized operation



Leonardo Dueñas-Osorio



# RESILIENCY

4 R's

**R**obustness – Inherent strength


**R**edundancy – Alternate options

**R**esourcefulness – Mobilize Resources

**R**apidity – Recovery Time

**MITIGATION  
EFFORT**



**SYSTEM DESIGN LEVEL**





# The Oregon Resilience Plan

## Reducing Risk and Improving Recovery for the Next Cascadia Earthquake and Tsunami



# Oregon Resilience Plan

KEY TO THE TABLE									
Desired time to restore component to 80-90% operational - In 50 Years								Resilient	G
Desired time to restore component to 50-60% operational - In 50 Years								Resilient	Y
Desired time to restore component to 20-30% operational - In 50 Years								Resilient	R
Current state restoration to 90% operational								Today	X

TARGET STATES OF RECOVERY									
Event Occurs	0-24 Hours	1 - 3 Days	3-7 Days	1 - 3 Weeks	3 Weeks - 1 Month	1 Month - 3 Months	3Months - 6 Months	6 Months - 1 year	1 year - 3 Years

[illegible]



# THE CENTER FOR RISK-BASED COMMUNITY RESILIENCE PLANNING

## A NIST-FUNDED CENTER OF EXCELLENCE

### University Partners:


Colorado State University

Cal Poly Pomona

University of Illinois

University of Oklahoma

Oregon State University



Rice University

Univer. of South Alabama

Texas A&M University

Texas A&M Kingsville

University of Washington

### Scope:

Identify the key components and attributes within communities that make them resilient to hazards, develop the NIST Community Resilience Modeling Environment (NIST-CORE) to support risk-informed resilience decisions. (Infrastructure independence, response, and recovery)



The  
End